

# Ventilation remote control FBR12-LFT

## Connection diagram & Setup for the SCHNEID-MC01

4. UART interface (COM-D) in the form of RS485.

Executed on the PLC (12V +/- RS485 D + / D-).

Used for direct connection of a digital SCHNEID FBR12-LFT.

### Baud rate setting

The baud rate for the MC01 should not be higher than 38400. There are no further changes required.

